



**NOTES:**

1. FIRE HYDRANT SHALL BE AMERICAN DARLING B-62 OR WATEROUS PACER WB67-250.
2. ALL HYDRANTS INSTALLED WITH BASE ELBOW IN OR BELOW THE WATER TABLE SHALL BE REQUIRED TO HAVE WEEP HOLES PLUGGED.
3. OWNER/HYDRANT USER WILL BE REQUIRED TO PUMP HYDRANT EMPTY BEFORE EACH WINTER SEASON. COORDINATE REQUIREMENTS WITH PUBLIC WORKS.

CITY OF WATFORD CITY, NORTH DAKOTA PUBLIC WORKS DEPARTMENT	
FIRE HYDRANT	
APPROVED FOR PUBLICATION	DWG. NO.
_____ City Engineer	Date
900-4	