



NOTES:

1. CONTRACTOR SHALL COMPLY WITH CURRENT OSHA TRENCH REGULATIONS.
2. DEWATERING SHALL BE IMPLEMENTED IN AREAS OF HIGH GROUNDWATER.
3. TRENCH ZONE BACKFILL MAY VARY.
4. COMPACT TO MIN. 95% MAX. DRY DENSITY IN MAX. 1 FOOT LIFTS UNDER PAVED SURFACES. COMPACT TO MIN. 90% MAX. DRY DENSITY IN MAX. 1 FOOT LIFTS UNDER NON-PAVED SURFACES.
5. MIN. 95% DRY DENSITY COMPACTION.

CITY OF WATFORD CITY, NORTH DAKOTA
PUBLIC WORKS DEPARTMENT

OPEN-CUT TRENCH SECTION

APPROVED FOR PUBLICATION

DWG. NO.

City Engineer

Date

900-7